## Manganese Levels in Northfield's Drinking Water



 Manganese was required to be tested in Northfield's water in 2019 and 2020. City also tested in 2020 results below

Well Number	Manganese Level (ug/L)
02	23.7 – 58
03	116 - 205
04	119 – 344*
05	77 – 97.2
06	83 - 129

<sup>\*</sup>Well 04 sample result of 344 ug/L was presumed to be a chunk of manganese in the water

## Manganese in Northfield's Tap Water



- City conducted testing in 5 locations throughout 2020 at taps where people drank water
  - No documentation on what type of treatment, if any, took place prior to the tap
- 4 of 5 sites had tests over 100 ug/L.